FREQUENCY CONVERTER SPECIFICATION
GEORATOR CORPORATION

MANASSAS, VIRGINIA 20110

MODEL NO. 36-006
TYPE 18-A ALTERNATOR

1.0 OUTPUT:

1.1 Rating: 1.0 KVA, 100% P.F., I Phase, 400 Hz, 115V (Nom.), 1714 RPM
1.2 Current Rating: 8.7 Amperes
1.3 Insulation: Class B
1.4 Duty: Cont.
1.5 Dielectric Strength, Winding to Frame: 1500V for 1 Min.

2.0 ROTOR BALANCE: 0.001

3.0 BEARINGS: Sealed Life Time Lubricated

4.0 FINISH:

4.1 Primer: Iridite
4.2 Paint: Silver-Blue Enamel
4.3 Fasteners: Zinc Plt.

5.0 WEIGHT:

5.1 Net: 46 Lbs.
5.2 Shipping: 61 Lbs.

Revision Letter	Date	Revision Description

ENGINEER	M.T.E.
APPROVED BY	April 20, 1998